



The Municipality of Lambton Shores

9577 Port Franks Road, Thedford ON
Telephone: (519) 243-1400
Email: afarr@lambtonshores.ca
[The Municipality of Lambton Shores](http://www.lambtonshores.ca)

RFT 2025-02 – Port Franks Marina Septic System Addendum No. 1

Plan takers should note the following:

1. Loading rate requirements to be done as per Table 8.7.4.1. Minimum 645 square meters is required.
2. **Question: Drawings calls one pump in each pump chamber – assuming they need to be grinder pumps to pump solids as well – no spec's given for the pump – do you have a preference?**

The minimum required pump capacity is 120 L/min @ TDH = 2.8m, as specified on the drawing. With the 50mm discharge lines, the raw sewage pumps should be grinder pumps.

3. **Question: In lieu of the performance bond (100%) and labour and material bond (100%). Can two certified cheques each for the full amount of the contract be provided at time of tender?**

Yes, the Municipality will accept two certified cheques each for the full amount of the contract at the time of tender.

January 28, 2025

Proponent's Signature _____ Date _____
(Bidders shall sign and date all addenda and attach copies to the submitted Proposal)
(emailed to all registered Plan Takers – 1 page)

